

Sample No : 674315  
Tel : 012 428-6010  
Report No : BCT 160714-00024 A  
File No : 2538/3543 I/MT16  
Page : 1  
Date : 2021-06-20

# TEST REPORT

CLAYVILLE BRICK  
128 Kruger road  
President Park  
Midrand

**CONCRETE MASONRY UNITS**  
**SANS 1215: 2008**  
**MARK No: 7663**

## 1 SIGNIFICANCE OF TEST RESULTS CONTAINED IN THIS REPORT

- 1.1 Refer to the print on the back of this page.
- 1.2 To determine whether the sample received complies with the requirements of SANS1215: 2008 "Concrete-Masonry Units".

## 2 CONCLUSION

- 2.1 The sample tested complies with all the requirements of SANS1215: 2008 "Concrete-Masonry Units" with respect to class 7,0 MPa Uncertainty of measurement was not applied to the results.

## 3 SAMPLE

### DESCRIPTION OF SAMPLE

Sixty cement masonry units with nominal dimensions "290 mm x 140 mm x 90 mm"



1 Dr Lategan Road, Groenkloof, Private Bag X191, Pretoria, 0001.  
Tel +27 12 428 7911. Fax +27 12 344 1568

SABS Commercial SOC Ltd conducted a conformity assessment pertaining to a sample of the product, commodity or system identified and the outcome recorded in this test report only relates to that specified sample. The conformity assessment outcomes recorded in the test report do not imply SABS Approval of the quality and/or performance of the sample(s) in question and the test results do not apply to any similar sample that has not been tested. (Refer also to the conditions of test printed on the back of this page.) This report may not be reproduced except in full. The authenticity of this report and its contents can be confirmed by contacting the person who signed it.